0214356.04 Issue Date: August 2023

ADDENDUM NO. 2

NOTICE is hereby given to prospective Bidders of the following information, clarifications, and modifications to the Bidding Documents for the Phase VII-B Water Main Replacements project. The Bidding Documents remain unchanged except as indicated below. Bidders must acknowledge receipt of this Addendum in the Bid Form and comply with the requirements for submission of Bids as set forth in the Bidding Documents.

CLARIFICATIONS

NOTICE is hereby given of the following clarifications to the Bidding Documents and addenda.

For Item 15 on Addendum 1, note that recycled imported fill materials may be used provided they meet the requirements of all specification sections and they receive approval during the submittal phase by the Engineer.

Item 17 in Addendum 1 states that services on White Plains Road are generally anticipated to be 6". This refers to services whose sizes are not otherwise stated on the drawings. Additional payments for services larger than 6" shall only be made where the service size was not stated on the drawings. Some services on White Plains Road are 8" and are specified as such on the drawings. Existing services shall be excavated and removed completely, except for where new services are directionally-drilled. Existing services to be replaced by directionally-drilled services shall be capped and abandoned in place. Directionally-drilled service installation methods shall be subject to review and approval by the Engineer during the submittal phase. The Contractor shall provide a detailed directional drilling plan with proposed equipment and methodologies.

MODIFICATIONS

NOTICE is hereby given that the Bidding Documents have been modified as follows.

The bid due date and bid opening have been changed to 11:00 a.m. on September 8th, 2023.

This Addendum and items listed above are provided to Bidders in a single Portable Document Format (.PDF).

Prepared and Issued by Woodard & Curran (Engineer) on behalf of Owner:

Village of Tarrytown, New York